



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J1G0557

DeRuyter Central Schools

Project Name: Drinking Water

Kevin Springer
711 Railroad Street
DeRuyter, NY 13052

Project / PO Number: N/A
Received: 06/25/2021
Reported: 07/28/2021

Analytical Testing Parameters

Client Sample ID:	01	Collected By:	Customer
Sample Matrix:	Drinking Water	Collection Date:	06/23/2021 6:05
Lab Sample ID:	J1G0557-01		

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0036	0.015 AL	0.0010	mg/L		07/20/21 1500	07/20/21 1815	LLW

Client Sample ID:	02	Collected By:	Customer
Sample Matrix:	Drinking Water	Collection Date:	06/23/2021 6:05
Lab Sample ID:	J1G0557-02		

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0011	0.015 AL	0.0010	mg/L		07/20/21 1500	07/20/21 1820	LLW

Client Sample ID:	03	Collected By:	Customer
Sample Matrix:	Drinking Water	Collection Date:	06/23/2021 6:06
Lab Sample ID:	J1G0557-03		

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0045	0.015 AL	0.0010	mg/L		07/20/21 1500	07/20/21 1822	LLW

Client Sample ID:	04	Collected By:	Customer
Sample Matrix:	Drinking Water	Collection Date:	06/23/2021 6:07
Lab Sample ID:	J1G0557-04		

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.015 AL	0.0010	mg/L		07/20/21 1500	07/20/21 1824	LLW

Microbac Laboratories, Inc.

3821 Buck Dr. | Cortland, NY 13045 | 607-753-3403 p | www.microbac.com



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J1G0557

Client Sample ID: 05	Collected By: Customer
Sample Matrix: Drinking Water	Collection Date: 06/23/2021 6:07
Lab Sample ID: J1G0557-05	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.015 AL	0.0010	mg/L		07/20/21 1500	07/20/21 1826	LLW

Client Sample ID: 06	Collected By: Customer
Sample Matrix: Drinking Water	Collection Date: 06/23/2021 6:08
Lab Sample ID: J1G0557-06	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.015 AL	0.0010	mg/L		07/20/21 1500	07/20/21 1828	LLW

Client Sample ID: 07	Collected By: Customer
Sample Matrix: Drinking Water	Collection Date: 06/23/2021 6:08
Lab Sample ID: J1G0557-07	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0012	0.015 AL	0.0010	mg/L		07/20/21 1500	07/20/21 1833	LLW

Client Sample ID: 08	Collected By: Customer
Sample Matrix: Drinking Water	Collection Date: 06/23/2021 6:09
Lab Sample ID: J1G0557-08	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0011	0.015 AL	0.0010	mg/L		07/20/21 1500	07/20/21 1835	LLW



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J1G0557

Client Sample ID: 09	Collected By: Customer
Sample Matrix: Drinking Water	Collection Date: 06/23/2021 6:10
Lab Sample ID: J1G0557-09	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.015 AL	0.0010	mg/L		07/20/21 1500	07/20/21 1837	LLW

Client Sample ID: 010	Collected By: Customer
Sample Matrix: Drinking Water	Collection Date: 06/23/2021 6:10
Lab Sample ID: J1G0557-10	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0014	0.015 AL	0.0010	mg/L		07/20/21 1500	07/20/21 1839	LLW

Client Sample ID: 011	Collected By: Customer
Sample Matrix: Drinking Water	Collection Date: 06/23/2021 6:11
Lab Sample ID: J1G0557-11	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0021	0.015 AL	0.0010	mg/L		07/20/21 1500	07/20/21 1841	LLW

Client Sample ID: 012	Collected By: Customer
Sample Matrix: Drinking Water	Collection Date: 06/23/2021 6:12
Lab Sample ID: J1G0557-12	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0062	0.015 AL	0.0051	mg/L	D	07/20/21 1500	07/22/21 1823	LLW



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J1G0557

Client Sample ID: 013	Collected By: Customer
Sample Matrix: Drinking Water	Collection Date: 06/23/2021 6:12
Lab Sample ID: J1G0557-13	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0194	0.015 AL	0.0010	mg/L		07/20/21 1500	07/20/21 1846	LLW

Client Sample ID: 014	Collected By: Customer
Sample Matrix: Drinking Water	Collection Date: 06/23/2021 6:13
Lab Sample ID: J1G0557-14	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0198	0.015 AL	0.0010	mg/L		07/20/21 1500	07/20/21 1848	LLW

Client Sample ID: 015	Collected By: Customer
Sample Matrix: Drinking Water	Collection Date: 06/23/2021 6:14
Lab Sample ID: J1G0557-15	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0154	0.015 AL	0.0010	mg/L		07/20/21 1500	07/20/21 1850	LLW

Client Sample ID: 016	Collected By: Customer
Sample Matrix: Drinking Water	Collection Date: 06/23/2021 6:14
Lab Sample ID: J1G0557-16	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0107	0.015 AL	0.0051	mg/L	D	07/20/21 1500	07/22/21 1828	LLW



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J1G0557

Client Sample ID: 017	Collected By: Customer
Sample Matrix: Drinking Water	Collection Date: 06/23/2021 6:15
Lab Sample ID: J1G0557-17	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0239	0.015 AL	0.0010	mg/L		07/20/21 1500	07/20/21 1858	LLW

Client Sample ID: 018	Collected By: Customer
Sample Matrix: Drinking Water	Collection Date: 06/23/2021 6:16
Lab Sample ID: J1G0557-18	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0097	0.015 AL	0.0051	mg/L	D	07/20/21 1500	07/22/21 1834	LLW

Client Sample ID: 019	Collected By: Customer
Sample Matrix: Drinking Water	Collection Date: 06/23/2021 6:17
Lab Sample ID: J1G0557-19	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0032	0.015 AL	0.0010	mg/L		07/20/21 1500	07/20/21 1902	LLW

Client Sample ID: 020	Collected By: Customer
Sample Matrix: Drinking Water	Collection Date: 06/23/2021 6:17
Lab Sample ID: J1G0557-20	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.015 AL	0.0010	mg/L		07/20/21 1500	07/20/21 1903	LLW



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J1G0557

Client Sample ID: 021	Collected By: Customer
Sample Matrix: Drinking Water	Collection Date: 06/23/2021 6:18
Lab Sample ID: J1G0557-21	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0023	0.015 AL	0.0010	mg/L		07/20/21 1502	07/20/21 1913	LLW

Client Sample ID: 022	Collected By: Customer
Sample Matrix: Drinking Water	Collection Date: 06/23/2021 6:19
Lab Sample ID: J1G0557-22	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.410	0.015 AL	0.0010	mg/L		07/20/21 1502	07/20/21 1919	LLW

Client Sample ID: 023	Collected By: Customer
Sample Matrix: Drinking Water	Collection Date: 06/23/2021 6:19
Lab Sample ID: J1G0557-23	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0099	0.015 AL	0.0051	mg/L	D	07/20/21 1502	07/22/21 1843	LLW

Client Sample ID: 024	Collected By: Customer
Sample Matrix: Drinking Water	Collection Date: 06/23/2021 6:20
Lab Sample ID: J1G0557-24	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0112	0.015 AL	0.0010	mg/L		07/20/21 1502	07/20/21 1922	LLW



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J1G0557

Client Sample ID: 025	Collected By: Customer
Sample Matrix: Drinking Water	Collection Date: 06/23/2021 6:21
Lab Sample ID: J1G0557-25	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0015	0.015 AL	0.0010	mg/L		07/20/21 1502	07/20/21 1924	LLW

Client Sample ID: 026	Collected By: Customer
Sample Matrix: Drinking Water	Collection Date: 06/23/2021 6:21
Lab Sample ID: J1G0557-26	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0274	0.015 AL	0.0010	mg/L		07/20/21 1502	07/20/21 1926	LLW

Client Sample ID: 027	Collected By: Customer
Sample Matrix: Drinking Water	Collection Date: 06/23/2021 6:22
Lab Sample ID: J1G0557-27	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0028	0.015 AL	0.0010	mg/L		07/20/21 1502	07/20/21 1932	LLW

Client Sample ID: 028	Collected By: Customer
Sample Matrix: Drinking Water	Collection Date: 06/23/2021 6:22
Lab Sample ID: J1G0557-28	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0051	0.015 AL	0.0051	mg/L	D	07/20/21 1502	07/22/21 1849	LLW



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J1G0557

Client Sample ID: 029	Sample Matrix: Drinking Water	Collected By: Customer
Lab Sample ID: J1G0557-29		Collection Date: 06/23/2021 6:23

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0095	0.015 AL	0.0010	mg/L		07/20/21 1502	07/20/21 1936	LLW

Client Sample ID: 030	Sample Matrix: Drinking Water	Collected By: Customer
Lab Sample ID: J1G0557-30		Collection Date: 06/23/2021 6:24

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0047	0.015 AL	0.0010	mg/L		07/20/21 1502	07/20/21 1938	LLW

Client Sample ID: 031	Sample Matrix: Drinking Water	Collected By: Customer
Lab Sample ID: J1G0557-31		Collection Date: 06/23/2021 6:24

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0111	0.015 AL	0.0020	mg/L	D	07/20/21 1502	07/22/21 1852	LLW

Client Sample ID: 032	Sample Matrix: Drinking Water	Collected By: Customer
Lab Sample ID: J1G0557-32		Collection Date: 06/23/2021 6:25

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0033	0.015 AL	0.0010	mg/L		07/20/21 1502	07/20/21 1943	LLW



Microbac Laboratories, Inc., New York Division
CERTIFICATE OF ANALYSIS
 J1G0557

Client Sample ID: 033	Sample Matrix: Drinking Water	Collected By: Customer
Lab Sample ID: J1G0557-33		Collection Date: 06/23/2021 6:26

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0013	0.015 AL	0.0010	mg/L		07/20/21 1502	07/20/21 1945	LLW

Client Sample ID: 034	Sample Matrix: Drinking Water	Collected By: Customer
Lab Sample ID: J1G0557-34		Collection Date: 06/23/2021 6:27

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0127	0.015 AL	0.0010	mg/L		07/20/21 1502	07/20/21 1947	LLW

Client Sample ID: 035	Sample Matrix: Drinking Water	Collected By: Customer
Lab Sample ID: J1G0557-35		Collection Date: 06/23/2021 6:27

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0102	0.015 AL	0.0102	mg/L	D	07/20/21 1502	07/26/21 1257	LLW

Client Sample ID: 036	Sample Matrix: Drinking Water	Collected By: Customer
Lab Sample ID: J1G0557-36		Collection Date: 06/23/2021 6:28

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0046	0.015 AL	0.0010	mg/L		07/20/21 1502	07/20/21 1955	LLW



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J1G0557

Client Sample ID: 037	Collected By: Customer
Sample Matrix: Drinking Water	Collection Date: 06/23/2021 6:28
Lab Sample ID: J1G0557-37	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0106	0.015 AL	0.0010	mg/L		07/20/21 1502	07/20/21 1957	LLW

Client Sample ID: 038	Collected By: Customer
Sample Matrix: Drinking Water	Collection Date: 06/23/2021 6:29
Lab Sample ID: J1G0557-38	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0123	0.015 AL	0.0010	mg/L		07/20/21 1502	07/20/21 1958	LLW

Client Sample ID: 039	Collected By: Customer
Sample Matrix: Drinking Water	Collection Date: 06/23/2021 6:29
Lab Sample ID: J1G0557-39	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.015 AL	0.0010	mg/L		07/20/21 1502	07/20/21 2000	LLW

Client Sample ID: 040	Collected By: Customer
Sample Matrix: Drinking Water	Collection Date: 06/23/2021 6:30
Lab Sample ID: J1G0557-40	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0084	0.015 AL	0.0010	mg/L		07/20/21 1502	07/20/21 2002	LLW

Microbac Laboratories, Inc.

3821 Buck Dr. | Cortland, NY 13045 | 607-753-3403 p | www.microbac.com



Microbac Laboratories, Inc., New York Division
CERTIFICATE OF ANALYSIS
 J1G0557

Client Sample ID: 041	Collected By: Customer
Sample Matrix: Drinking Water	Collection Date: 06/23/2021 6:30
Lab Sample ID: J1G0557-41	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0047	0.015 AL	0.0010	mg/L		07/20/21 1503	07/20/21 2012	LLW

Client Sample ID: 042	Collected By: Customer
Sample Matrix: Drinking Water	Collection Date: 06/23/2021 6:30
Lab Sample ID: J1G0557-42	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.015 AL	0.0010	mg/L		07/20/21 1503	07/20/21 2018	LLW

Client Sample ID: 043	Collected By: Customer
Sample Matrix: Drinking Water	Collection Date: 06/23/2021 6:31
Lab Sample ID: J1G0557-43	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.015 AL	0.0010	mg/L		07/20/21 1503	07/20/21 2020	LLW

Client Sample ID: 044	Collected By: Customer
Sample Matrix: Drinking Water	Collection Date: 06/23/2021 6:31
Lab Sample ID: J1G0557-44	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0209	0.015 AL	0.0010	mg/L		07/20/21 1503	07/20/21 2021	LLW



Microbac Laboratories, Inc., New York Division
CERTIFICATE OF ANALYSIS
 J1G0557

Client Sample ID: 045	Collected By: Customer
Sample Matrix: Drinking Water	Collection Date: 06/23/2021 6:32
Lab Sample ID: J1G0557-45	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0059	0.015 AL	0.0010	mg/L		07/20/21 1503	07/20/21 2023	LLW

Client Sample ID: 046	Collected By: Customer
Sample Matrix: Drinking Water	Collection Date: 06/23/2021 6:32
Lab Sample ID: J1G0557-46	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0045	0.015 AL	0.0010	mg/L		07/20/21 1503	07/20/21 2025	LLW

Client Sample ID: 047	Collected By: Customer
Sample Matrix: Drinking Water	Collection Date: 06/23/2021 6:33
Lab Sample ID: J1G0557-47	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0254	0.015 AL	0.0010	mg/L		07/20/21 1503	07/20/21 2031	LLW

Client Sample ID: 048	Collected By: Customer
Sample Matrix: Drinking Water	Collection Date: 06/23/2021 6:34
Lab Sample ID: J1G0557-48	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0075	0.015 AL	0.0010	mg/L		07/20/21 1503	07/20/21 2033	LLW



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J1G0557

Client Sample ID: 049
Sample Matrix: Drinking Water
Lab Sample ID: J1G0557-49

Collected By: Customer
Collection Date: 06/23/2021 6:35

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0081	0.015 AL	0.0010	mg/L		07/20/21 1503	07/20/21 2035	LLW

Client Sample ID: 050
Sample Matrix: Drinking Water
Lab Sample ID: J1G0557-50

Collected By: Customer
Collection Date: 06/23/2021 6:36

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0028	0.015 AL	0.0010	mg/L		07/20/21 1503	07/20/21 2037	LLW

Client Sample ID: 051
Sample Matrix: Drinking Water
Lab Sample ID: J1G0557-51

Collected By: Customer
Collection Date: 06/23/2021 6:37

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0089	0.015 AL	0.0010	mg/L		07/20/21 1503	07/20/21 2039	LLW

Client Sample ID: 052
Sample Matrix: Drinking Water
Lab Sample ID: J1G0557-52

Collected By: Customer
Collection Date: 06/23/2021 6:38

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0141	0.015 AL	0.0010	mg/L		07/20/21 1503	07/20/21 2043	LLW



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J1G0557

Client Sample ID: 053	Collected By: Customer
Sample Matrix: Drinking Water	Collection Date: 06/23/2021 6:39
Lab Sample ID: J1G0557-53	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0221	0.015 AL	0.0010	mg/L		07/20/21 1503	07/20/21 2045	LLW

Client Sample ID: 054	Collected By: Customer
Sample Matrix: Drinking Water	Collection Date: 06/23/2021 6:41
Lab Sample ID: J1G0557-54	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.015 AL	0.0010	mg/L		07/20/21 1503	07/20/21 2046	LLW

Client Sample ID: 055	Collected By: Customer
Sample Matrix: Drinking Water	Collection Date: 06/23/2021 6:43
Lab Sample ID: J1G0557-55	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.015 AL	0.0010	mg/L		07/20/21 1503	07/20/21 2048	LLW

Client Sample ID: 056	Collected By: Customer
Sample Matrix: Drinking Water	Collection Date: 06/23/2021 6:45
Lab Sample ID: J1G0557-56	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0051	0.015 AL	0.0010	mg/L		07/20/21 1503	07/20/21 2054	LLW



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J1G0557

Client Sample ID: 057	Collected By: Customer
Sample Matrix: Drinking Water	Collection Date: 06/23/2021 6:10
Lab Sample ID: J1G0557-57	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0042	0.015 AL	0.0020	mg/L	D	07/20/21 1503	07/22/21 1903	LLW

Client Sample ID: 058	Collected By: Customer
Sample Matrix: Drinking Water	Collection Date: 06/23/2021 6:12
Lab Sample ID: J1G0557-58	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0026	0.015 AL	0.0010	mg/L		07/20/21 1503	07/20/21 2058	LLW

Client Sample ID: 059	Collected By: Customer
Sample Matrix: Drinking Water	Collection Date: 06/23/2021 6:12
Lab Sample ID: J1G0557-59	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0011	0.015 AL	0.0010	mg/L		07/20/21 1503	07/20/21 2100	LLW

Client Sample ID: 060	Collected By: Customer
Sample Matrix: Drinking Water	Collection Date: 06/24/2021 6:13
Lab Sample ID: J1G0557-60	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0020	0.015 AL	0.0020	mg/L	D	07/20/21 1503	07/22/21 1907	LLW



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J1G0557

Client Sample ID: 061	Collected By: Customer
Sample Matrix: Drinking Water	Collection Date: 06/24/2021 6:13
Lab Sample ID: J1G0557-61	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0022	0.015 AL	0.0010	mg/L		07/21/21 1013	07/21/21 1030	LLW

Client Sample ID: 062	Collected By: Customer
Sample Matrix: Drinking Water	Collection Date: 06/24/2021 6:14
Lab Sample ID: J1G0557-62	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0013	0.015 AL	0.0010	mg/L		07/21/21 1013	07/21/21 1036	LLW

Client Sample ID: 063	Collected By: Customer
Sample Matrix: Drinking Water	Collection Date: 06/24/2021 6:15
Lab Sample ID: J1G0557-63	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0050	0.015 AL	0.0010	mg/L		07/21/21 1013	07/21/21 1038	LLW

Client Sample ID: 064	Collected By: Customer
Sample Matrix: Drinking Water	Collection Date: 06/24/2021 6:15
Lab Sample ID: J1G0557-64	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0018	0.015 AL	0.0010	mg/L		07/21/21 1013	07/21/21 1040	LLW



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J1G0557

Client Sample ID: 065	Collected By: Customer
Sample Matrix: Drinking Water	Collection Date: 06/24/2021 6:16
Lab Sample ID: J1G0557-65	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0402	0.015 AL	0.0010	mg/L		07/21/21 1013	07/21/21 1041	LLW

Client Sample ID: 066	Collected By: Customer
Sample Matrix: Drinking Water	Collection Date: 06/24/2021 6:16
Lab Sample ID: J1G0557-66	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0470	0.015 AL	0.0010	mg/L		07/21/21 1013	07/21/21 1043	LLW

Client Sample ID: 067	Collected By: Customer
Sample Matrix: Drinking Water	Collection Date: 06/24/2021 6:17
Lab Sample ID: J1G0557-67	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0596	0.015 AL	0.0010	mg/L		07/22/21 1338	07/23/21 2015	LLW

Client Sample ID: 068	Collected By: Customer
Sample Matrix: Drinking Water	Collection Date: 06/24/2021 6:17
Lab Sample ID: J1G0557-68	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0462	0.015 AL	0.0010	mg/L		07/22/21 1338	07/23/21 2021	LLW



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J1G0557

Client Sample ID: 069	Collected By: Customer
Sample Matrix: Drinking Water	Collection Date: 06/24/2021 6:18
Lab Sample ID: J1G0557-69	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0177	0.015 AL	0.0010	mg/L		07/21/21 1013	07/21/21 1049	LLW

Client Sample ID: 070	Collected By: Customer
Sample Matrix: Drinking Water	Collection Date: 06/24/2021 6:18
Lab Sample ID: J1G0557-70	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0523	0.015 AL	0.0010	mg/L		07/21/21 1013	07/21/21 1051	LLW

Client Sample ID: 071	Collected By: Customer
Sample Matrix: Drinking Water	Collection Date: 06/24/2021 6:19
Lab Sample ID: J1G0557-71	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0213	0.015 AL	0.0010	mg/L		07/21/21 1013	07/21/21 1052	LLW

Client Sample ID: 072	Collected By: Customer
Sample Matrix: Drinking Water	Collection Date: 06/24/2021 6:20
Lab Sample ID: J1G0557-72	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0558	0.015 AL	0.0010	mg/L		07/22/21 1338	07/23/21 2023	LLW



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J1G0557

Client Sample ID: 073	Collected By: Customer
Sample Matrix: Drinking Water	Collection Date: 06/24/2021 6:20
Lab Sample ID: J1G0557-73	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0937	0.015 AL	0.0010	mg/L		07/21/21 1013	07/21/21 1054	LLW

Client Sample ID: 074	Collected By: Customer
Sample Matrix: Drinking Water	Collection Date: 06/24/2021 6:21
Lab Sample ID: J1G0557-74	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0539	0.015 AL	0.0010	mg/L		07/22/21 1338	07/23/21 2025	LLW

Client Sample ID: 075	Collected By: Customer
Sample Matrix: Drinking Water	Collection Date: 06/24/2021 6:22
Lab Sample ID: J1G0557-75	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0670	0.015 AL	0.0010	mg/L		07/22/21 1338	07/23/21 2026	LLW

Client Sample ID: 076	Collected By: Customer
Sample Matrix: Drinking Water	Collection Date: 06/24/2021 6:22
Lab Sample ID: J1G0557-76	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0644	0.015 AL	0.0010	mg/L		07/22/21 1338	07/23/21 2028	LLW



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J1G0557

Client Sample ID: 077	Collected By: Customer
Sample Matrix: Drinking Water	Collection Date: 06/24/2021 6:23
Lab Sample ID: J1G0557-77	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0247	0.015 AL	0.0020	mg/L	D	07/21/21 1013	07/22/21 1913	LLW

Client Sample ID: 078	Collected By: Customer
Sample Matrix: Drinking Water	Collection Date: 06/24/2021 6:23
Lab Sample ID: J1G0557-78	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0175	0.015 AL	0.0010	mg/L		07/21/21 1013	07/21/21 1100	LLW

Client Sample ID: 079	Collected By: Customer
Sample Matrix: Drinking Water	Collection Date: 06/24/2021 6:24
Lab Sample ID: J1G0557-79	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0292	0.015 AL	0.0010	mg/L		07/21/21 1013	07/21/21 1101	LLW

Client Sample ID: 080	Collected By: Customer
Sample Matrix: Drinking Water	Collection Date: 06/24/2021 6:24
Lab Sample ID: J1G0557-80	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0094	0.015 AL	0.0010	mg/L		07/21/21 1013	07/21/21 1103	LLW



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J1G0557

Client Sample ID: 081	Collected By: Customer
Sample Matrix: Drinking Water	Collection Date: 06/24/2021 6:25
Lab Sample ID: J1G0557-81	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	1.23	0.015 AL	0.0010	mg/L		07/21/21 1013	07/21/21 1105	LLW

Client Sample ID: 082	Collected By: Customer
Sample Matrix: Drinking Water	Collection Date: 06/24/2021 6:28
Lab Sample ID: J1G0557-82	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0026	0.015 AL	0.0020	mg/L	D	07/21/21 1013	07/22/21 1935	LLW

Client Sample ID: 083	Collected By: Customer
Sample Matrix: Drinking Water	Collection Date: 06/24/2021 6:28
Lab Sample ID: J1G0557-83	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0051	0.015 AL	0.0051	mg/L	D	07/21/21 1013	07/22/21 2037	LLW

Client Sample ID: 084	Collected By: Customer
Sample Matrix: Drinking Water	Collection Date: 06/24/2021 6:29
Lab Sample ID: J1G0557-84	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.015 AL	0.0010	mg/L		07/21/21 1013	07/21/21 1114	LLW

Microbac Laboratories, Inc.

3821 Buck Dr. | Cortland, NY 13045 | 607-753-3403 p | www.microbac.com



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J1G0557

Client Sample ID: 085	Sample Matrix: Drinking Water	Collected By: Customer
Lab Sample ID: J1G0557-85		Collection Date: 06/24/2021 6:30

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0166	0.015 AL	0.0010	mg/L		07/21/21 1013	07/21/21 1116	LLW

Client Sample ID: 086	Sample Matrix: Drinking Water	Collected By: Customer
Lab Sample ID: J1G0557-86		Collection Date: 06/24/2021 6:30

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0022	0.015 AL	0.0010	mg/L		07/21/21 1013	07/21/21 1118	LLW

Client Sample ID: 087	Sample Matrix: Drinking Water	Collected By: Customer
Lab Sample ID: J1G0557-87		Collection Date: 06/24/2021 6:31

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0131	0.015 AL	0.0010	mg/L		07/21/21 1051	07/21/21 1127	LLW

Client Sample ID: 088	Sample Matrix: Drinking Water	Collected By: Customer
Lab Sample ID: J1G0557-88		Collection Date: 06/24/2021 6:31

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0157	0.015 AL	0.0010	mg/L		07/21/21 1051	07/21/21 1133	LLW



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J1G0557

Client Sample ID: 089	Collected By: Customer
Sample Matrix: Drinking Water	Collection Date: 06/24/2021 6:33
Lab Sample ID: J1G0557-89	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.015 AL	0.0010	mg/L		07/21/21 1051	07/21/21 1134	LLW

Client Sample ID: 090	Collected By: Customer
Sample Matrix: Drinking Water	Collection Date: 06/24/2021 6:34
Lab Sample ID: J1G0557-90	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0025	0.015 AL	0.0010	mg/L		07/21/21 1051	07/21/21 1136	LLW

Client Sample ID: 091	Collected By: Customer
Sample Matrix: Drinking Water	Collection Date: 06/24/2021 6:35
Lab Sample ID: J1G0557-91	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0035	0.015 AL	0.0010	mg/L		07/21/21 1051	07/21/21 1138	LLW

Client Sample ID: 092	Collected By: Customer
Sample Matrix: Drinking Water	Collection Date: 06/24/2021 6:36
Lab Sample ID: J1G0557-92	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0131	0.015 AL	0.0010	mg/L		07/21/21 1051	07/21/21 1140	LLW

Microbac Laboratories, Inc.

3821 Buck Dr. | Cortland, NY 13045 | 607-753-3403 p | www.microbac.com



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J1G0557

Client Sample ID: 093	Collected By: Customer
Sample Matrix: Drinking Water	Collection Date: 06/24/2021 6:36
Lab Sample ID: J1G0557-93	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0014	0.015 AL	0.0010	mg/L		07/21/21 1051	07/21/21 1145	LLW

Client Sample ID: 094	Collected By: Customer
Sample Matrix: Drinking Water	Collection Date: 06/24/2021 6:37
Lab Sample ID: J1G0557-94	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0306	0.015 AL	0.0020	mg/L	D	07/21/21 1051	07/22/21 2040	LLW

Client Sample ID: 095	Collected By: Customer
Sample Matrix: Drinking Water	Collection Date: 06/24/2021 6:38
Lab Sample ID: J1G0557-95	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0250	0.015 AL	0.0250	mg/L	D	07/22/21 1338	07/26/21 1259	LLW

Client Sample ID: 096	Collected By: Customer
Sample Matrix: Drinking Water	Collection Date: 06/24/2021 6:39
Lab Sample ID: J1G0557-96	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0103	0.015 AL	0.0010	mg/L		07/21/21 1051	07/21/21 1149	LLW



Microbac Laboratories, Inc., New York Division
CERTIFICATE OF ANALYSIS
J1G0557

Client Sample ID: 097	Collected By: Customer
Sample Matrix: Drinking Water	Collection Date: 06/24/2021 6:39
Lab Sample ID: J1G0557-97	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.015 AL	0.0010	mg/L		07/21/21 1051	07/21/21 1151	LLW

Client Sample ID: 098	Collected By: Customer
Sample Matrix: Drinking Water	Collection Date: 06/24/2021 6:41
Lab Sample ID: J1G0557-98	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.015 AL	0.0010	mg/L		07/21/21 1051	07/21/21 1153	LLW

Client Sample ID: 099	Collected By: Customer
Sample Matrix: Drinking Water	Collection Date: 06/24/2021 7:00
Lab Sample ID: J1G0557-99	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0094	0.015 AL	0.0010	mg/L		07/21/21 1051	07/21/21 1156	LLW

Client Sample ID: 0100	Collected By: Customer
Sample Matrix: Drinking Water	Collection Date: 06/24/2021 7:01
Lab Sample ID: J1G0557-AA	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0023	0.015 AL	0.0010	mg/L		07/21/21 1051	07/21/21 1158	LLW



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J1G0557

Client Sample ID: 0101	Collected By: Customer
Sample Matrix: Drinking Water	Collection Date: 06/24/2021 7:05
Lab Sample ID: J1G0557-AB	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0032	0.015 AL	0.0010	mg/L		07/21/21 1051	07/21/21 1200	LLW

Client Sample ID: 0102	Collected By: Customer
Sample Matrix: Drinking Water	Collection Date: 06/24/2021 7:06
Lab Sample ID: J1G0557-AC	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0038	0.015 AL	0.0010	mg/L		07/21/21 1051	07/21/21 1202	LLW

Client Sample ID: 0103	Collected By: Customer
Sample Matrix: Drinking Water	Collection Date: 06/24/2021 7:07
Lab Sample ID: J1G0557-AD	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.015 AL	0.0010	mg/L		07/21/21 1051	07/21/21 1207	LLW

Client Sample ID: 0104	Collected By: Customer
Sample Matrix: Drinking Water	Collection Date: 06/24/2021 7:09
Lab Sample ID: J1G0557-AE	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0093	0.015 AL	0.0010	mg/L		07/21/21 1051	07/21/21 1209	LLW



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J1G0557

Client Sample ID: 0105	Collected By: Customer
Sample Matrix: Drinking Water	Collection Date: 06/24/2021 7:10
Lab Sample ID: J1G0557-AF	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.015 AL	0.0010	mg/L		07/21/21 1051	07/21/21 1211	LLW

Client Sample ID: 0106	Collected By: Customer
Sample Matrix: Drinking Water	Collection Date: 06/24/2021 7:10
Lab Sample ID: J1G0557-AG	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.015 AL	0.0010	mg/L		07/21/21 1051	07/21/21 1213	LLW

Client Sample ID: 0107	Collected By: Customer
Sample Matrix: Drinking Water	Collection Date: 06/24/2021 7:11
Lab Sample ID: J1G0557-AH	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0055	0.015 AL	0.0010	mg/L		07/21/21 1051	07/21/21 1215	LLW

Client Sample ID: 0108	Collected By: Customer
Sample Matrix: Drinking Water	Collection Date: 06/24/2021 7:12
Lab Sample ID: J1G0557-AI	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0188	0.015 AL	0.0010	mg/L		07/21/21 1529	07/21/21 2001	LLW

Microbac Laboratories, Inc.

3821 Buck Dr. | Cortland, NY 13045 | 607-753-3403 p | www.microbac.com



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J1G0557

Client Sample ID: 0109	Collected By: Customer
Sample Matrix: Drinking Water	Collection Date: 06/24/2021 7:13
Lab Sample ID: J1G0557-AJ	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0030	0.015 AL	0.0020	mg/L	D	07/21/21 1529	07/22/21 2023	LLW

Client Sample ID: 0110	Collected By: Customer
Sample Matrix: Drinking Water	Collection Date: 06/24/2021 7:14
Lab Sample ID: J1G0557-AK	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0020	0.015 AL	0.0010	mg/L		07/21/21 1529	07/21/21 2008	LLW

Client Sample ID: 0111	Collected By: Customer
Sample Matrix: Drinking Water	Collection Date: 06/24/2021 6:00
Lab Sample ID: J1G0557-AL	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0044	0.015 AL	0.0010	mg/L		07/21/21 1529	07/21/21 2010	LLW

Client Sample ID: 0112	Collected By: Customer
Sample Matrix: Drinking Water	Collection Date: 06/24/2021 6:01
Lab Sample ID: J1G0557-AM	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0057	0.015 AL	0.0010	mg/L		07/21/21 1529	07/21/21 2012	LLW

Results in bold have exceeded a limit defined for this project. Limits are provided for reference but as regulatory limits change frequently, Microbac Laboratories, Inc. advises the recipient of this report to confirm such limits and units of concentration with the appropriate Federal, state or local authorities before acting on the data.



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J1G0557

Definitions

- AL: US EPA Action Level
- D: The sample was diluted due to matrix interference.
- mg/L: Milligrams per Liter
- RL: Reporting Limit

Project Requested Certification(s)

Microbac Laboratories, Inc. - Dayville 11549	New York State Department of Health
Microbac Laboratories, Inc., New York Division NY Lab ID No.: 10795	New York State Department of Health

Report Comments

Samples were received in proper condition and the reported results conform to applicable accreditation standard unless otherwise noted.

The data and information on this, and other accompanying documents, represents only the sample(s) analyzed. This report is incomplete unless all pages indicated in the footnote are present and an authorized signature is included. The services were provided under and subject to Microbac's standard terms and conditions which can be located and reviewed at <<https://www.microbac.com/standard-terms-conditions>>.

Reviewed and Approved By:

Shannon Weeks
Customer Relationship Coordinator
Reported: 07/28/2021 12:03

Microbac Laboratories, Inc.

3821 Buck Dr. | Cortland, NY 13045 | 607-753-3403 p | www.microbac.com



CHAIN OF CUSTODY RECORD

DeRuyter Central Schools
PM: Shannon Weeks



Number: J 1 G 0 5 5 7

Instructions on back

Turnaround Time

TO BE COMPLETED BY INITIAL RECEIVING MICROBAC

Temperature Upon Receipt (°C):
Thermometer ID:
Receiving Lab: CRT HRG PTN SAY
Holding Time:
Samples Received on Ice? Yes No N/A
Custody Seal Intact? Yes No N/A

Report Type

Results Only
 Level 1 Level 2 Level 3 Level 4
 EMB

Compliance Monitoring? Yes No
If Yes: Agency/Program

PU No: 210506

Sampler Signature: Kevin Springer

Sampler Telephone No.: 315-852-3400 X 7301

Matrix Types: Drinking Water (DW), Groundwater (GW), Surface/Storm Water (SW), Wastewater (WW), Recreational Water (RW), Soil/Solid (S), Sludge (SL), Oil (O), Wipe (W), Other (specify)
Preservative Types: HNO3(1), H2SO4(2), HCl(3), NaOH(4), Sodium Thiosulfate(5), Ammonium Chloride(6), Ammonium Sulfate(7), EDA(8), Hexane(9), Methanol(10), Sodium Bisulfate(11), Sodium Sulfite(12), Zinc Acetate(13), Unpreserved (U), Other (specify)

REQUESTED ANALYSIS

Lab ID	Client Sample ID	Date Collected	Time Collected	No. of Containers	Matrix	Grab / Composite	Preservative	Sample or position	Received By (signature)	Date/Time	Additional Notes
1		6/23/21	6:05	1	DW	Grab U					Dishwasher sink
2		6/23/21	6:05	1	DW	Grab U					Hand wash sink
3			6:06	1	DW	Grab U					Food prep Sink
4			6:07	1	DW	Grab U					Cafe DF
5			6:07	1	DW	Grab U					Cafe BF
6			6:08	1	DW	Grab U					Gym Hall Girls DF

Possible Hazard Identification: Hazardous Non Hazardous Radiocative
Requisitioned by (signature): _____ Date/Time: _____
Requisitioned by (signature): _____ Date/Time: _____
Requisitioned by (signature): _____ Date/Time: _____

TO BE COMPLETED BY INITIAL RECEIVING MICROBAC:
Temperature Upon Receipt (°C): _____ Same as Above
Thermometer ID: _____
Receiving Lab: CRT HRG PTN SAY
Samples Received on Ice? Yes No N/A

TO BE COMPLETED BY INITIAL RECEIVING MICROBAC:

TO BE COMPLETED BY FINAL RECEIVING MICROBAC:

Lab Report Address: **De Ruyter Central School**

Client Name: **De Ruyter Central School**
 Address: **711 Railroad St.**
 City, State, Zip: **De Ruyter, NY 13052**
 Contact: **Kevin Springer**
 Telephone No.: **315-852-3400 x7301**
 Report Email: **springer@deruytercentral.org**
 Send Report via: Mail Fax E-mail

Temperature Upon Receipt (°C):
 Thermometer ID:
 Receiving Lab: **CRT HBG PTN SAY**
 Holding Time:
 Samples Received on Ice? **Yes No N/A**
 Custody Seals Intact? **Yes No N/A**

Turnaround Time:
 Routine (5-7 bus. days)
 RUSH* (notify lab)
SAME
 Report Type:
 Results Only
 Level 1 Level 2 Level 3 Level 4
 EDD

Project: **De Ruyter School**
 Location: **De Ruyter School**
 PO No. **210506**
 Compliance Monitoring? Yes No
 If Yes: Agency/Program:
 Sampler Signature: **Kevin Springer**
 Sampler Telephone No.: **315-852-3400 x 7301**

Matrix: **Drinking Water (DW), Groundwater (GW), Surface/Storm Water (SW), Wastewater (WW), Recreational Water (RC), Soil/Solid (S), Sludge (SL), Oil (O), Wipe (W), Other (specify)**
 Preservative Types: **HNO3(1), H2SO4(2), HCl(3), NaOH(4), Sodium Thiosulfate(5), Ammonium Chloride(6), Ammonium Sulfate(7), EDA(8), Hexane(9), Methanol(10), Sodium Bisulfate(11), Sodium Sulfite(12), Zinc Acetate(13), Unpreserved (U), Other (specify)**

REQUESTED ANALYSIS

Lab ID	Client Sample ID	Date Collected	Time Collected	No. of Containers	Matrix	Grab / Composite	Preservative	Lead Testing
7		6/23/21	6:08	1	DW	Grab	U	↓
8			6:09			↓	↓	↓
9			6:10			↓	↓	↓
10			6:10			↓	↓	↓
11			6:11			↓	↓	↓
12			6:12			↓	↓	↓

Possible Hazard Identification	Relinquished By (signature)	Date/Time	Relinquished By (signature)	Date/Time	Relinquished By (signature)	Date/Time	Sample Disposition	Received By (signature)	Date/Time	Additional Notes
							<input type="checkbox"/> Hazardous <input type="checkbox"/> Non-Hazardous <input type="checkbox"/> Radioactive			
										Gym Hall Girls - Sink Left
										Gym Hall Girls - Sink Rt
										Boys DF - Gym Hall
										Gym Hall - Boys Sink Left
										Gym Hall - Boys Sink Rt.
										Boys Coach Bathroom Sink
										[] Archive

*** If initial and final receiving Microbac are the same, check "Same as Above" in Final Receiving Box.
 *** TO BE COMPLETED BY FINAL RECEIVING MICROBAC:
 Temperature Upon Receipt (°C):
 Thermometer ID:
 Receiving Lab: **CRT PTN**
 Samples Received on Ice? **Yes No N/A**
 Same as Above

Lab Report Address

Turnaround Time

TO BE COMPLETED BY INITIAL RECEIVING MICROBAC:

Client Name: **De Ruyter Central School**
 Address: **711 Railroad St.**
 City, State, Zip: **De Ruyter, NY 13052**
 Contact: **Kevin Springer**
 Telephone No.: **315-852-3400 x7301**
 Report Email: **springer@deruytercentral.org**
 Send Report via: Mail Fax E-mail

Client Name: **SAME**
 Address: **SAME**
 City, State, Zip:
 Contact:
 Telephone No.:
 Invoice Email:
 Send Invoice via: Mail Fax E-mail

Temperature Upon Receipt (°C):
 Thermometer ID:
 Receiving Lab: **CRT HBG PTN SAY**
 Holding Time:
 Samples Received on Ice? **Yes No N/A**
 Custody Seals Intact? **Yes No N/A**
 Compliance Monitoring? Yes No
 If Yes: Agency/Program:
 Sampler Telephone No.: **315-852-3400 x 7301**

Project: **De Ruyter School** PO No. **210506**
 Location: **De Ruyter School** Sampler Signature: **Kevin Springer**
 Sampled by (PRINT): **Kevin Springer**
 Matrix Types: **Drinking Water (DW), Groundwater (GW), Surface/Storm Water (SW), Wastewater (WW), Recreational Water (RC), Soil/Solid (S), Sludge (SL), Oil (O), Wipe (W), Other (specify)**
 Preservative Types: **HNO3(1), H2SO4(2), HCl(3), NaOH(4), Sodium Thiosulfate(5), Ammonium Chloride(6), Ammonium Sulfate(7), EDA(8), Hexane(9), Methanol(10), Sodium Bisulfate(11), Sodium Sulfite(12), Zinc Acetate(13), Unpreserved (U), Other (specify)**

REQUESTED ANALYSIS

Lab ID	Client Sample ID	Date Collected	Time Collected	No. of Containers	Matrix	Grab / Composite	Preservative	Additional Notes
13		6/23/21	6:12	1	DW	Grab	U	Boys Lockerroom Sink
14			6:13	1	DW	Grab	U	Boys Lockerroom DF
15			6:14	1	DW	Grab	U	Girls Lockerroom DF
16			6:14	1	DW	Grab	U	Girls Lockerroom Sink
17			6:15	1	DW	Grab	U	Girls Wash Bath Sink
18			6:16	1	DW	Grab	U	Student Medical Sink

Possible Hazard Identification Hazardous Non-Hazardous Radioactive

Comments:

Sample Disposition Dispose as appropriate Return Archive
 Relinquished By (signature) Date/Time Received By (signature) Date/Time
 Relinquished By (signature) Date/Time Received By (signature) Date/Time
 Relinquished By (signature) Date/Time Received By (signature) Date/Time

**** TO BE COMPLETED BY FINAL RECEIVING MICROBAC:**
 Temperature Upon Receipt (°C):
 Thermometer ID:
 Receiving Lab: **CRT PTN**
 Samples Received on Ice? **Yes No N/A**
 Same as Above

Lab Report Address

Client Name: **De Ruyter Central School**
 Address: **711 Railroad St.**
 City, State, Zip: **De Ruyter, N.Y. 13052**
 Contact: **Kevin Springer**
 Telephone No.: **315-852-3400 x7301**
 Report Email: **springer@deruytercentral.org**
 Send Report via: Mail Fax E-mail

Turnaround Time

Routine (5-7 bus. days)
 RUSH* (notify lab)

Result Type

Results Only
 Level 1 Level 2 Level 3 Level 4
 EDD

TO BE COMPLETED BY INITIAL RECEIVING MICROBAC:

Temperature Upon Receipt (°C):
 Thermometer ID:
 Receiving Lab: **CRT HBG PTN SAY**
 Holding Time:
 Samples Received on Ice? **Yes No N/A**
 Custody Seals Intact? **Yes No N/A**

Project:

Location: **De Ruyter School** PO No. **210506** Compliance Monitoring? Yes No
 Agency/Program:

Sampled by (PRINT): **Kevin Springer**

Sampler Signature: *Kevin Springer* Sampler Telephone No.: **315-852-3400 x 7301**
 Matrix Types: Drinking Water (DW), Groundwater (GW), Surface/Storm Water (SW), Wastewater (WW), Recreational Water (RC), Soil/Solid (S), Sludge (SL), Oil (O), Wipe (W), Other (specify)
 Preservative Types: HNO3(1), H2SO4(2), HCl(3), NaOH(4), Sodium Thiosulfate(5), Ammonium Chloride(6), Ammonium Sulfate(7), EDA(8), Hexane(9), Methanol(10), Sodium Bisulfate(11), Sodium Sulfite(12), Zinc Acetate(13), Unpreserved (U), Other (specify)

REQUESTED ANALYSIS

Lab ID	Client Sample ID	Date Collected	Time Collected	No. of Containers	Matrix	Grab / Composite	Preservative	Lead Testing
19		6/23/21	6:17	1	DW Grab	U		↓
20			6:17					↓
21			6:18					↓
22			6:19					↓
23			6:19					↓
24			6:20					↓

Additional Notes
 Staff Bath sink
 Nurse Bath sink
 Nurse sink
 RM-113 class sink
 RM-113 bath sink
 RM-114 bath sink
 Archive

Possible Hazard Identification Hazardous Non-Hazardous Radioactive

Comments:

Sample Disposition Dispose as appropriate Return Archive
 Received By (signature) Date/Time
 Relinquished By (signature) Date/Time
 Relinquished By (signature) Date/Time
 Relinquished By (signature) Date/Time

** TO BE COMPLETED BY FINAL RECEIVING MICROBAC:
 Temperature Upon Receipt (°C):
 Thermometer ID:
 Receiving Lab: **CRT PTN**
 Samples Received on Ice? **Yes No N/A**
 Same as Above

TO BE COMPLETED BY INITIAL RECEIVING MICROBAC:

Turnaround Time

Invoice Address

Temperature Upon Receipt (°C):
Thermometer ID:
Receiving Lab: CRT HBG PTN SAY
Holding Time:
Samples Received on Ice? Yes No N/A
Custody Seals Intact? Yes No N/A

Routine (5-7 bus. days)
 RUSH* (notify lab)

Client Name:

SAME

Lab Report Address

Client Name: **De Ruyter Central School**
Address: **711 Railroad St.**
City, State, Zip: **De Ruyter, NY 13052**
Contact: **Kevin Springer**
Telephone No.: **315-852-3400 x7301**
Report Email: **springer@deruytercentral.org**
Send Report via: Mail Fax E-mail

Compliance Monitoring? Yes No
If Yes: Agency/Program:

PO No. **210506**

Location: **De Ruyter School**

Project:

Sampler Telephone No.: **315-852-3400 x 7301**

Sampler Signature: *Kevin Springer*

Sampled by (PRINT): **Kevin Springer**

Matrix Types: Drinking Water (DW), Groundwater (GW), Surface/Storm Water (SW), Wastewater (WW), Recreational Water (RC), Soil/Solid (S), Sludge (SL), Oil (O), Wipe (W), Other (specify)
Preservative Types: HNO3(1), H2SO4(2), HCl(3), NaOH(4), Sodium Thiosulfate(5), Ammonium Chloride(6), Ammonium Sulfate(7), EDA(8), Hexane(9), Methanol(10), Sodium Bisulfate(11), Sodium Sulfite(12), Zinc Acetate(13), Unpreserved (U), Other (specify)

REQUESTED ANALYSIS

Lab ID	Client Sample ID	Date Collected	Time Collected	No. of Containers	Matrix	Grab / Composite	Preservative	Lead Testing
	25	6/23/21	6:21	1	DW	Grab U		↓
	26		6:21					↓
	27		6:22					↓
	28		6:22					↓
	29		6:23					↓
	30		6:24					↓

Additional Notes
RM-115 Class sink
RM-115 Bath sink
RM-116 Class sink
RM-116 Bath sink
RM-117 Bath sink
RM-118 Class sink

Possible Hazard Identification	Sample Disposition	Received By (signature)	Date/Time
<input type="checkbox"/> Hazardous <input type="checkbox"/> Non-Hazardous <input type="checkbox"/> Radioactive	<input type="checkbox"/> Dispose as appropriate <input type="checkbox"/> Return <input type="checkbox"/> Archive		
Relinquished By (signature)	Received By (signature)		
Relinquished By (signature)	Received By (signature)		
Relinquished By (signature)	Received By (signature)		

** TO BE COMPLETED BY FINAL RECEIVING MICROBAC:
 Temperature Upon Receipt (°C):
 Thermometer ID:
 Receiving Lab: CRT PTN
 Samples Received on Ice? Yes No N/A

If Initial and Final Receiving Microbac are the same, check "Same as Above" in Final Receiving Box.

Lab Report Address Invoice Address **Turnaround Time**

Client Name: DeRuyter Central School
Address: 711 Railroad St.
City, State, Zip: DeRuyter, NY 13052
Contact: Kevin Springer
Telephone No.: 315-852-3400 x 7301
Report Email: springer@deruytercentral.org
Send Report via: [] Mail [] Fax [X] E-mail
Client Name: SAME
Address: [] Routine (5-7 bus, days) [X] RUSH* (notify lab)
City, State, Zip: [] Level 1 [] Level 2 [] Level 3 [] Level 4
Contact: [] Results Only
Telephone No.: [] Level 1 [] Level 2 [] Level 3 [] Level 4
Report Email: [] EDD
Send Invoice via: [] Mail [] Fax [] E-mail

Project: DeRuyter School PO No. 210506 Compliance Monitoring? [] Yes [] No
Location: DeRuyter School PO No. 210506 If Yes: Agency/Program:
Sampler Signature: Kevin Springer Sampler Telephone No.: 315-852-3400 x 7301
Matrix Types: Drinking Water (DW), Groundwater (GW), Surface/Storm Water (SW), Wastewater (WW), Recreational Water (RC), Soil/Solid (S), Oil (O), Wipe (W), Other (specify)
Preservative Types: HNO3(1), H2SO4(2), HCl(3), NaOH(4), Sodium Thiosulfate(5), Ammonium Chloride(6), Ammonium Sulfate(7), EDA(8), Hexane(9), Methanol(10), Sodium Bisulfate(11), Sodium Sulfite(12), Zinc Acetate(13), Unpreserved (U), Other (specify)

REQUESTED ANALYSIS

Lab ID	Client Sample ID	Date Collected	Time Collected	No. of Containers	Matrix	Grab / Composite	Reservable	Lead Testing
31		6/23/21	6:24	1	DW Grab U			
32			6:25					
33			6:26					
34			6:27					
35			6:27					
36			6:28					

Additional Notes
 Rm. 118 Bath sink
 Elem. wing Staff Bath
 Rm. 121 Class sink
 Rm. 120 Bath sink
 Rm. 120 Class sink
 Rm. 123 Class sink

Possible Hazard Identification [] Hazardous [] Non-Hazardous [] Radioactive
Comments:
 Relinquished By (signature) Date/Time
 Relinquished By (signature) Date/Time
 Relinquished By (signature) Date/Time
 Received By (signature) Date/Time
 Received By (signature) Date/Time
 Received By (signature) Date/Time

TO BE COMPLETED BY INITIAL RECEIVING MICROBAC:
 Temperature Upon Receipt (°C):
 Thermometer ID:
 Receiving Lab: CRT HBG PTN SAY
 Holding Time:
 Samples Received on Ice? Yes No N/A
 Custody Seals Intact? Yes No N/A

TO BE COMPLETED BY FINAL RECEIVING MICROBAC:
 Temperature Upon Receipt (°C):
 Thermometer ID:
 Receiving Lab: CRT PTN
 Samples Received on Ice? Yes No N/A

Lab Report Address Invoice Address

Client Name: **De Ruyter Central School**
 Address: **711 Railroad St.**
 City, State, Zip: **De Ruyter, NY 13052**
 Contact: **Kevin Springer**
 Telephone No.: **315-852-3400 x 7301**
 Report Email: **springer@deruytercentral.org**
 Send Report via: Mail Fax E-mail

Turnaround Time
 Routine (5-7 bus. days)
 RUSH* (notify lab)
 Report Type
 Results Only
 Level 1 Level 2 Level 3 Level 4
 EDD

TO BE COMPLETED BY INITIAL RECEIVING MICROBAC:
 Temperature Upon Receipt (°C):
 Thermometer ID:
 Receiving Lab: **CRT HBG PTN SAY**
 Holding Time:
 Samples Received on Ice? **Yes No N/A**
 Custody Seals Intact? **Yes No N/A**

Project: **De Ruyter School** PO No. **210506** Compliance Monitoring? Yes No
 If Yes: Agency/Program:
 Sampled by (PRINT): **Kevin Springer** Sampler Signature: *Kevin Springer* Sampler Telephone No.: **315-852-3400 x 7301**
 Matrix Types: **Drinking Water (DW), Groundwater (GW), Surface/Storm Water (SW), Wastewater (WW), Recreational Water (RC), Soil/Solid (S), Sludge (SL), Oil (O), Wipe (W), Other (specify)**
 Preservative Types: **HNO3(1), H2SO4(2), HCl(3), NaOH(4), Sodium Thioisulfate(5), Ammonium Chloride(6), Ammonium Sulfate(7), EDA(8), Hexane(9), Methanol(10), Sodium Bisulfate(11), Sodium Sulfite(12), Zinc Acetate(13), Unpreserved (U), Other (specify)**

REQUESTED ANALYSIS

Lab ID	Client Sample ID	Date Collected	Time Collected	No. of Containers	Matrix	Grab / Composite	Preservative	Lead Testing
37	62321	6:28	6:28	1	DW Grab U	U		
38		6:29	6:29					
39		6:29	6:29					
40		6:30	6:30					
41		6:30	6:30					
42		6:30	6:30					

Additional Notes
 Rm 123 Bath sink
 Rm 128 Class sink
 Boys Gang DF
 Boys Gang Sink left
 Sink Middle
 Sink right

Possible Hazard Identification Hazardous Non-Hazardous Radioactive
 Relinquished By (signature) _____ Date/Time _____
 Relinquished By (signature) _____ Date/Time _____
 Relinquished By (signature) _____ Date/Time _____
 Relinquished By (signature) _____ Date/Time _____
 Relinquished By (signature) _____ Date/Time _____

Comments:

TO BE COMPLETED BY FINAL RECEIVING MICROBAC:
 Temperature Upon Receipt (°C):
 Thermometer ID:
 Receiving Lab: **CRT PTN**
 Samples Received on Ice? **Yes No N/A**



CHAIN OF CUSTODY RECORD

Number Instructions on back

TO BE COMPLETED BY INITIAL RECEIVING MICROBAC:

Temperature Upon Receipt (°C):
Thermometer ID:
Receiving Lab: CRT HBG PTN SAY
Holding Time:
Samples Received on Ice? Yes No N/A
Custody Seals Intact? Yes No N/A

Turnaround Time

Routine (5-7 bus. days)
 RUSH* (notify lab)

Report Type

Results Only
 Level 1 Level 2 Level 3 Level 4
 JEDO

Lab Report Address

Client Name: De Ruyter Central School

Address: 711 Railroad St.

City, State, Zip: De Ruyter, NY 13052

Contact: Kevin Springer

Telephone No.: 315-852-3400 x 7301

Report Email: springer@deruytercentral.org

Send Report via: Mail Fax E-mail

Send Invoiced via: Mail Fax E-mail

Project:

Location: De Ruyter School PO No. 210506 Compliance Monitoring? Yes No
If Yes: Agency/Program:

Sampled by (PRINT): Kevin Springer

Sampler Signature: Kevin Springer

Sampler Telephone No.: 315-852-3400 x 7301

* Matrix Types: Drinking Water (DW), Groundwater (GW), Surface/Storm Water (SW), Wastewater (WW), Recreational Water (RC), Soil/Solid (S), Sludge (SL), Oil (O), Wipe (W), Other (specify)
** Preservative Types: HNO3(1), H2SO4(2), HCl(3), NaOH(4), Sodium Thiosulfate(5), Ammonium Chloride(6), Ammonium Sulfate(7), EDA(8), Hexane(9), Methanol(10), Sodium Bisulfate(11), Sodium Sulfite(12), Zinc Acetate(13), Unpreserved (U), Other (specify)

REQUESTED ANALYSIS

Lab ID	Client Sample ID	Date Collected	Time Collected	No. of Containers	Matrix *	Grab / Composites	Preservative **	Lead Testing
43		6/23/21	6:31	1	DW	Grab U		↓
44			6:31					↓
45			6:32					↓
46			6:32					↓
47			6:33					↓
48			6:34					↓

Additional Notes
Girls Gang DF
Girls Gang Both left Sink
Back Middle
Both Right
Rm. 134 Class sink
Rm. 135 Class sink

Possible Hazard Identification Hazardous Non-Hazardous Radioactive

Comments:

Sample Disposition	Date/Time	Received By (signature)	Date/Time
<input type="checkbox"/> Dispose as appropriate			
<input type="checkbox"/> Return			
Relinquished By (signature)			
Relinquished By (signature)			
Relinquished By (signature)			

** TO BE COMPLETED BY FINAL RECEIVING MICROBAC:
Temperature Upon Receipt (°C):
Thermometer ID:
Receiving Lab: CRT PTN
Samples Received on Ice? Yes No N/A

*** If Initial and Final Receiving Microbac are the same, check "Same as Above" in Final Receiving Box.

Lab Report Address

Client Name: **De Ruyter Central School**
 Address: **711 Railroad St.**
 City, State, Zip: **De Ruyter, NY 13052**
 Contact: **Kevin Springer**
 Telephone No.: **315-852-3400 x 7301**
 Report Email: **springer@deruytercentral.org**
 Send Report via: Mail Fax E-mail

Turnaround Time

Routine (5-7 bus. days)
 'RUSH' (notify lab)

Report Type

Results Only
 Level 1 Level 2 Level 3 Level 4
 EDD

Invoice Address

Client Name: **SAME**
 Address:
 City, State, Zip:
 Contact:
 Telephone No.:
 Invoice Email:
 Send Invoice via: Mail Fax E-mail

Project:

Location: **De Ruyter School** PO No. **210506** Compliance Monitoring? Yes No
 If Yes: Agency/Program:


Sampled by (PRINT): **Kevin Springer**

Sampler Signature: *Kevin Springer*

Sampler Telephone No.: **315-852-3400 x 7301**

- Matrix Types:** Drinking Water (DW), Groundwater (GW), Surface/Storm Water (SW), Wastewater (WW), Recreational Water (RC), Soil/Solid (S), Sludge (SL), Oil (O), Wipe (W), Other (specify)
Preservative Types: HNO3(1), H2SO4(2), HCl(3), NaOH(4), Sodium Thiosulfate(5), Ammonium Chloride(6), Ammonium Sulfate(7), EDA(8), Hexane(9), Methanol(10), Sodium Bisulfate(11), Sodium Sulfite(12), Zinc Acetate(13), Unpreserved (U), Other (specify)

REQUESTED ANALYSIS



Lab ID	Client Sample ID	Date Collected	Time Collected
49		6/23/21	6:35
50			6:36
51			6:37
52			6:38
53			6:39
54			6:41

Possible Hazard Identification Hazardous Non-Hazardous Radioactive

Comments:

Reinquinished By (signature)
 Date/Time

Sample Disposition Dispose as appropriate Return Archive
 Received By (signature)
 Date/Time

Received By (signature)
 Date/Time

Additional Notes

Rm-136 Class sink
 Rm-139 Class sink
 Rm-137 Class sink
 Rm-138 Class sink
 Rm-131 Class sink
 1st DF Elem. wing

**** TO BE COMPLETED BY FINAL RECEIVING MICROBAC:**
 Temperature Upon Receipt ("C):
 Thermometer ID:
 Receiving Lab: **CRT PTN**
 Samples Received on Ice? **Yes No N/A**

**** TO BE COMPLETED BY INITIAL RECEIVING MICROBAC:**
 Temperature Upon Receipt ("C):
 Thermometer ID:
 Receiving Lab: **CRT PTN**
 Samples Received on Ice? **Yes No N/A**

Lab Report Address

Client Name: **DeRuyter Central School**
 Address: **711 Railroad St.**
 City, State, Zip: **DeRuyter, NY 13052**
 Contact: **Kevin Springer**
 Telephone No.: **315-852-3400 x 7301**
 Report Email: **springer@deruytercentral.org**
 Send Report via: Mail Fax E-mail

Invoice Address

Client Name: **SAME**
 Address: **SAME**
 City, State, Zip:
 Contact:
 Telephone No.:
 Invoicer Email:
 Send Invoice via: Mail Fax E-mail

Turnaround Time

Routine (5-7 bus. days)
 RUSH* (notify lab)

Report Type

Results Only
 Level 1 Level 2 Level 3 Level 4
 EDD

Project:

Location: **DeRuyter School** PO No. **210506** Compliance Monitoring? Yes No
 if Yes: Agency/Program:

Sampled by (PRINT): **Kevin Springer**

Sampler Signature: *Kevin Springer*

Sampler Telephone No.: **315-852-3400 x 7301**

* Matrix Types: Drinking Water (DW), Groundwater (GW), Surface/Storm Water (SW), Wastewater (WW), Recreational Water (RC), Soil/Solid (S), Sludge (SL), Oil (O), Wipe (W), Other (specify)
 ** Preservative Types: HNO3(1), H2SO4(2), HCl(3), NaOH(4), Sodium Thiosulfate(5), Ammonium Chloride(6), Ammonium Sulfate(7), EDA(8), Hexane(9), Methanol(10), Sodium Bisulfate(11), Sodium Sulfite(12), Zinc Acetate(13), Unpreserved (U), Other (specify)

REQUESTED ANALYSIS

Lab ID	Client Sample ID	Date Collected	Time Collected	No. of Containers	Matrix	Grab / Composite	Preservative	Lead Testing	Additional Notes
55		6/23/21	6:43	1	DW	Grab U			Small 9Y in DF
56		6/23/21	6:45	1	DW	Grab U			LMC sink
57		6/24/21	6:10	1	DW	Grab U			Rm-130 Bath sink
58		6/24/21	6:12	1	DW	Grab U			Rm-109 Left sink
59		6/24/21	6:12	1	DW	Grab U			Rm-109 Right sink
60		6/24/21	6:13	1	DW	Grab U			H5 Girls Bath left sink

Possible Hazard Identification Hazardous Non-Hazardous Radioactive

Comments:

Sample Disposition	Date/Time	Received By (signature)	Date/Time
<input type="checkbox"/> Dispose as appropriate <input type="checkbox"/> Return <input type="checkbox"/> Archive			

** TO BE COMPLETED BY FINAL RECEIVING MICROBAC:
 Temperature Upon Receipt (°C): Same as Above []
 Thermometer ID:
 Receiving Lab: CRT PTN
 Samples Received on Ice? Yes No N/A

Lab Report Address Invoice Address

Client Name: **DeRuyter Central School**
 Address: **711 Railroad St.**
 City, State, Zip: **DeRuyter, NY 13052**
 Contact: **Kevin Springer**
 Telephone No.: **315-852-3400 x 7301**
 Report Email: **springer@deruytercentral.org**
 Send Report via: Mail Fax E-mail

Client Name: **SAME**
 Address:
 City, State, Zip:
 Contact:
 Telephone No.:
 Invoice Email:
 Send Invoice via: Mail Fax E-mail

Turnaround Time

Routine (5-7 bus. days)
 RUSH* (notify lab)
 Receiving Lab: **CRT HBG PTN SAY**
 Holding Time:
 Samples Received on Ice? **Yes No N/A**
 Custody Seals Intact? **Yes No N/A**

Report Type

Results Only
 Level 1 Level 2 Level 3 Level 4
 EDD

Project: **DeRuyter School** PO No. **210506** Compliance Monitoring? Yes No
 If Yes: Agency/Program:
 Sampler Telephone No.: **315-852-3400 x 7301**
 *Matrix Types: Drinking Water (DW), Groundwater (GW), Surface/Storm Water (SW), Wastewater (WW), Recreational Water (RC), Soil/Solid (S), Oil (O), Wipe (W), Other (specify)
 **Preservative Types: HNO3(1), H2SO4(2), HCl(3), NaOH(4), Sodium Thiosulfate(5), Ammonium Chloride(6), Ammonium Sulfate(7), EDA(8), Hexane(9), Methanol(10), Sodium Bisulfate(11), Sodium Sulfite(12), Zinc Acetate(13), Unpreserved (U), Other (specify)

REQUESTED ANALYSIS

Lab ID	Client Sample ID	Date Collected	Time Collected	No. of Containers	Matrix	Grab / Composite	Testative?	Lead Testing
61		6/24/21	6:13	1	DW	Grab		
62			6:14					
63			6:15					
64			6:15					
65			6:16					
66			6:16					

Additional Notes
 HS Girls Bath Right sink
 HS Boys Bath L sink
 HS Boys Bath R sink
 Staff Bath Sink
 Rm-102 / ab table 1
 Rm-102 / ab table 2

Possible Hazard Identification	Sample Disposition	Date/Time	Received By (signature)	Date/Time
<input type="checkbox"/> Hazardous <input type="checkbox"/> Non-Hazardous <input type="checkbox"/> Radioactive	<input type="checkbox"/> Dispose as appropriate <input type="checkbox"/> Return <input type="checkbox"/> Archive			
Comments:				

*** TO BE COMPLETED BY FINAL RECEIVING MICROBAC:
 Temperature Upon Receipt (°C):
 Thermometer ID:
 Receiving Lab: **CRT PTN**
 Samples Received on Ice? **Yes No N/A**

*** TO BE COMPLETED BY INITIAL RECEIVING MICROBAC:
 Temperature Upon Receipt (°C):
 Thermometer ID:
 Receiving Lab: **CRT PTN**
 Samples Received on Ice? **Yes No N/A**

Number Instructions on back

TO BE COMPLETED BY INITIAL RECEIVING MICROBAC:

Turnaround Time

Temperature Upon Receipt (°C):
Thermometer ID:
Receiving Lab: GRT HBG PTN SAY
Holding Time:
Samples Received on Ice? Yes No N/A
Custody Seals Intact? Yes No N/A

Invoice Address

Client Name: **SAME**
Address:
City, State, Zip:
Contact:
Telephone No.:
Invoice Email:
Send Invoice via: Mail Fax E-mail

Lab Report Address

Client Name: **De Ruyter Central School**
Address: **711 Railroad St.**
City, State, Zip: **De Ruyter, NY 13052**
Contact: **Kevin Springer**
Telephone No.: **315-852-3400 x7301**
Report Email: **springer@deruytercentral.org**
Send Report via: Mail Fax E-mail

Compliance Monitoring? Yes No
If Yes: Agency/Program:

PO No. **210506**

Location: **De Ruyter School**

Project:

Sampler Telephone No.: **315-852-3400 x 7301**

Sampler Signature: **Kevin Springer**

Sampled by (PRINT): **Kevin Springer**

Matrix Types: Drinking Water (DW), Groundwater (GW), Surface/Storm Water (SW), Wastewater (WW), Recreational Water (RC), Soil/Solid (S), Sludge (SL), Oil (O), Wipe (W), Other (specify)
Preservative Types: HNO3(1), H2SO4(2), HCl(3), NaOH(4), Sodium Thiosulfate(5), Ammonium Chloride(6), Ammonium Sulfate(7), EDA(8), Hexane(9), Methanol(10), Sodium Bisulfate(11), Sodium Sulfite(12), Zinc Acetate(13), Unpreserved (U), Other (specify)

REQUESTED ANALYSIS

Lab ID	Client Sample ID	Date Collected	Time Collected	No. of Containers	Matrix	Grab / Composite	Preservative	Lead Testing
	67	6/24/21	6:17	1	DW	Grab		
	68		6:17					
	69		6:18					
	70		6:18					
	71		6:19					
	72		6:20					

Additional Notes
Rm. 102 Lab table 3
Rm. 102 Lab table 4
Rm. 102 Outside left
Rm. 102 Outside back
Rm. 102 Outside Right
Rm. 102 Teachers Station

Possible Hazard Identification Hazardous Non-Hazardous Radioactive

Comments:	Received By (signature)	Date/Time	Received By (signature)	Date/Time	Received By (signature)	Date/Time

*** TO BE COMPLETED BY FINAL RECEIVING MICROBAC:
Temperature Upon Receipt (°C):
Thermometer ID:
Receiving Lab: GRT PTN
Samples Received on Ice? Yes No N/A

*** If Initial and Final Receiving Microbac are the same, check "Same as Above" in Final Receiving Box.

Lab Report Address

Client Name: **De Ruyter Central School**
 Address: **711 Railroad St.**
 City, State, Zip: **De Ruyter, NY 13052**
 Contact: **Kevin Springer**
 Telephone No.: **315-852-3400 x 7301**
 Report Email: **springer@deruytercentral.org**

Invoice Address

Client Name: **SAME**
 Address: **SAME**
 City, State, Zip:
 Contact:
 Telephone No.:
 Invoice Email:

Turnaround Time

Routine (5-7 bus. days)
 RUSH* (notify lab)

Report Type

Results Only
 Level 1 Level 2 Level 3 Level 4
 EDD

Send Report via: Mail Fax E-mail

Send Invoice via: Mail Fax E-mail

Project:

Location: **De Ruyter School** PO No. **210506** Compliance Monitoring? Yes No
 Agency/Program:

Sampled by (PRINT): **Kevin Springer**

Sampler Signature: *Kevin Springer*

Sampler Telephone No.: **315-852-3400 x 7301**

Matrix Types: Drinking Water (DW), Groundwater (GW), Surface/Storm Water (SW), Wastewater (WW), Recreational Water (RC), Soil/Solid (S), Sludge (SL), Oil (O), Wipe (W), Other (specify)
Preservative Types: HNO3(1), H2SO4(2), HCl(3), NaOH(4), Sodium Thiosulfate(5), Ammonium Chloride(6), Ammonium Sulfate(7), EDA(8), Hexane(9), Methanol(10), Sodium Bisulfate(11), Sodium Sulfite(12), Zinc Acetate(13), Unpreserved (U), Other (specify)

REQUESTED ANALYSIS

Lab ID	Client Sample ID	Date Collected	Time Collected	# of Containers	Matrix	Grab / Composite	Preservative	Lead Testing
73		6/24/21	6:20	1	DW	Grab		
74			6:21					
75			6:22					
76			6:22					
77			6:23					
78			6:23					

Additional/Notes

Rm. 102 Storage
 Rm. 101 lab table 1
 Rm. 101 lab table 2
 Rm. 101 lab table 3
 Rm. 101 Outside left
 Rm. 101 Outside Middle

Possible Hazard Identification

Hazardous Non-Hazardous Radioactive

Comments:

Sample Disposition	Date/Time	Received By (signature)	Date/Time
<input type="checkbox"/> Dispose as appropriate <input type="checkbox"/> Return <input type="checkbox"/> Archive			
Relinquished By (signature)		Relinquished By (signature)	
Relinquished By (signature)		Relinquished By (signature)	

*** TO BE COMPLETED BY FINAL RECEIVING MICROBAC:
 Temperature Upon Receipt ("C):
 Thermometer ID:
 Receiving Lab: CRT PTN
 Samples Received on Ice? Yes No N/A

*** If Initial and Final Receiving Microbac are the same, check "Same as Above" in Final Receiving Box.

TO BE COMPLETED BY INITIAL RECEIVING MICROBAC:

Turnaround Time

Lab Report Address Invoice Address

Temperature Upon Receipt (°C):
Thermometer ID:
Receiving Lab: CRT HBG PTN SAY
Holding Time:
Samples Received on Ice? Yes No N/A
Custody Seals Intact? Yes No N/A

☑ Routine (5-7 bus. days)
☐ RUSH* (notify lab)

Client Name: **SAME**
Address:
City, State, Zip:
Contact:
Telephone No.:

Compliance Monitoring? ☐ Yes ☐ No
If Yes: Agency/Program:
Sampler Telephone No.: 315-852-3400 x 7301

☐ Level 1 ☐ Level 2 ☐ Level 3 ☐ Level 4
☐ EDD

Send Invoice via: ☐ Mail ☐ Fax ☐ E-mail
Location: **De Ruyter School** PO No. **210506**
Sampler Signature: *Kevin Springer*

Sampled by (PRINT): **Kevin Springer**

☐ Results Only

Project:
Matrix Issues: Drinking Water (DW), Groundwater (GW), Surface/Storm Water (SW), Wastewater (WW), Recreational Water (RC), Soil/Solid (S), Sludge (SL), Oil (O), Wipe (W), Other (specify)
Preservative Issues: HNO3(1), H2SO4(2), HCl(3), NaOH(4), Sodium Thiosulfate(5), Ammonium Chloride(6), Ammonium Sulfate(7), EDA(8), Hexane(9), Methanol(10), Sodium Bisulfate(11), Sodium Sulfite(12), Zinc Acetate(13), Unpreserved (U), Other (specify)

Additional Notes

Requested Analysis

Lab ID Client Sample ID Date Collected Time Collected

RM-101 Outside Right
RM-101 Front Left
RM-101 Teachers Station
HS Boys Bath Sink Left
HS Boys Bath Sink Right
Guidance DF

Lead Testing
Preservative
Grab / Composite
DW Grab U

79 6/24/21 6:24
80 6:24
81 6:25
82 6:28
83 6:28
84 6:29

Received By (signature) Date/Time

Received By (signature) Date/Time

Relinquished By (signature) Date/Time

Returned as appropriate ☐ Return ☐ Archive

Relinquished By (signature) Date/Time

Relinquished By (signature) Date/Time

Comments:

Comments:

Comments:

TO BE COMPLETED BY FINAL RECEIVING MICROBAC:

Temperature Upon Receipt (°C):
Thermometer ID:
Receiving Lab: CRT HBG PTN SAY
Samples Received on Ice? Yes No N/A

Client Name: **SAME**
Address:
City, State, Zip:
Contact:
Telephone No.:

Compliance Monitoring? ☐ Yes ☐ No
If Yes: Agency/Program:
Sampler Telephone No.: 315-852-3400 x 7301

☐ Level 1 ☐ Level 2 ☐ Level 3 ☐ Level 4
☐ EDD

Send Invoice via: ☐ Mail ☐ Fax ☐ E-mail
Location: **De Ruyter School** PO No. **210506**
Sampler Signature: *Kevin Springer*

Sampled by (PRINT): **Kevin Springer**

☐ Results Only

Project:
Matrix Issues: Drinking Water (DW), Groundwater (GW), Surface/Storm Water (SW), Wastewater (WW), Recreational Water (RC), Soil/Solid (S), Sludge (SL), Oil (O), Wipe (W), Other (specify)
Preservative Issues: HNO3(1), H2SO4(2), HCl(3), NaOH(4), Sodium Thiosulfate(5), Ammonium Chloride(6), Ammonium Sulfate(7), EDA(8), Hexane(9), Methanol(10), Sodium Bisulfate(11), Sodium Sulfite(12), Zinc Acetate(13), Unpreserved (U), Other (specify)

Additional Notes

Requested Analysis

Lab ID Client Sample ID Date Collected Time Collected

RM-101 Outside Right
RM-101 Front Left
RM-101 Teachers Station
HS Boys Bath Sink Left
HS Boys Bath Sink Right
Guidance DF

Lead Testing
Preservative
Grab / Composite
DW Grab U

79 6/24/21 6:24
80 6:24
81 6:25
82 6:28
83 6:28
84 6:29

Received By (signature) Date/Time

Received By (signature) Date/Time

Relinquished By (signature) Date/Time

Returned as appropriate ☐ Return ☐ Archive

Relinquished By (signature) Date/Time

Relinquished By (signature) Date/Time

Comments:

Comments:

Comments:

Instructions on back

TO BE COMPLETED BY INITIAL RECEIVING MICROBAC:

Temperature Upon Receipt (°C):
 Thermometer ID:
 Receiving Lab: GRT HBG PTN SAY
 Holding Time:
 Samples Received on Ice? Yes No N/A
 Custody Seals Intact? Yes No N/A

Turnaround Time

Routine (5-7 bus. days)
 RUSH* (notify lab)

Report Type

Results Only
 Level 1 Level 2 Level 3 Level 4
 EDD

Invoice Address

Client Name: **SAME**
 Address:
 City, State, Zip:
 Contact:
 Telephone No.:
 Invoice Email:
 *Send Invoice via: Mail Fax E-mail

Lab Report Address

Client Name: **DeRuyter Central School**
 Address: **711 Railroad St.**
 City, State, Zip: **DeRuyter, NY 13052**
 Contact: **Kevin Springer**
 Telephone No.: **315-852-3400 x7301**
 Report Email: **springer@deruytercentral.org**
 *Send Report via: Mail Fax E-mail

Project: **DeRuyter School** PO No. **210506** Compliance Monitoring? Yes No
 If Yes: Agency/Program:
 Sampled by (PRINT): **Kevin Springer** Sampler Signature: *Kevin Springer* Sampler Telephone No.: **315-852-3400 x 7301**
 *Matrix Types: Drinking Water (DW), Groundwater (GW), Surface/Storm Water (SW), Wastewater (WW), Recreational Water (RC), Soil/Solid (S), Sludge (SL), Oil (O), Wipe (W), Other (specify)
 **Preservative Types: HNO3(1), H2SO4(2), HCl(3), NaOH(4), Sodium Thiocyanate(5), Ammonium Chloride(6), Ammonium Sulfate(7), EDA(8), Hexameth(9), Methanol(10), Sodium Bisulfate(11), Sodium Sulfite(12), Zinc Acetate(13), Unpreserved (U), Other (specify)

REQUESTED ANALYSIS

Lab ID	Client Sample ID	Date Collected	Time Collected	No. of Containers	Matrix	Grab / Composite	Preservative	Additional Notes
85		6/24/21	6:30	1	DW Grab U			HS Girls Bath Sink left
86			6:30					HS Girls Bath Sink Right
87			6:31					HS Art sink left
88			6:31					HS Art sink right
89			6:33					Middle School DF
90			6:34					Middle School Staff

Possible Hazard Identification Hazardous Non-Hazardous Radioactive
 Relinquished By (signature) Date/Time
 Relinquished By (signature) Date/Time
 Relinquished By (signature) Date/Time

TO BE COMPLETED BY FINAL RECEIVING MICROBAC:
 Temperature Upon Receipt (°C):
 Thermometer ID:
 Receiving Lab: GRT HBG PTN SAY
 Samples Received on Ice? Yes No N/A



CHAIN OF CUSTODY RECORD

Lab Report Address

Client Name: De Ruyter Central School

Address: 711 Railroad St.

City, State, Zip: De Ruyter, NY 13052

Contact: Kevin Springer

Telephone No.: 315-852-3400 x 7301

Report Email: springer@deruytercentral.org

Send Report via: [] Mail [] Fax [X] E-mail

Invoice Address

Client Name: SAME

Address: SAME

City, State, Zip:

Contact:

Telephone No.:

Invoice Email:

Send Invoice via: [] Mail [] Fax [] E-mail

Location: De Ruyter School

PO No. 210506

Sampler Signature: Kevin Springer

Sampler Telephone No.: 315-852-3400 x 7301

Matrix Types: Drinking Water (DW), Groundwater (GW), Surface/Storm Water (SW), Wastewater (WW), Recreational Water (RC), Soil/Solid (S), Oil (O), Wipe (W), Other (specify)

Preservative Types: HNO3(1), H2SO4(2), HCl(3), NaOH(4), Sodium Thiosulfate(5), Ammonium Chloride(6), Ammonium Sulfate(7), EDA(8), Hexane(9), Methanol(10), Sodium Bisulfate(11), Sodium Sulfite(12), Zinc Acetate(13), Unpreserved (U), Other (specify)

Project: De Ruyter School

Compliance Monitoring? [] Yes [] No

If Yes: Agency/Program:

Additional Notes: Rm. 212 Outside Right Middle School Boys Left Middle School Boys Right Rm. 218 Rm. 220 Middle School Girls Left

Requested Analysis

Sample Disposition [] Dispose as appropriate [] Return [] Archive

Received By (signature)

Date/Time

Received By (signature)

Date/Time

Received By (signature)

Date/Time

Reinquinished By (signature)

Date/Time

Reinquinished By (signature)

Date/Time

Reinquinished By (signature)

Date/Time

Reinquinished By (signature)

Date/Time

Reinquinished By (signature)

Date/Time

Reinquinished By (signature)

Date/Time

TO BE COMPLETED BY INITIAL RECEIVING MICROBAC:

Temperature Upon Receipt (°C):

Thermometer ID:

Receiving Lab: CRT HBG PTN SAY

Samples Received on Ice? Yes No N/A

Instructions on back

Number

Temperature Upon Receipt (°C):

Thermometer ID:

Receiving Lab: CRT HBG PTN SAY

Samples Received on Ice? Yes No N/A

Custody Seals Intact? Yes No N/A

Level 1 [] Level 2 [] Level 3 [] Level 4 []

Compliance Monitoring? [] Yes [] No

If Yes: Agency/Program:

Sampler Telephone No.: 315-852-3400 x 7301

Matrix Types: Drinking Water (DW), Groundwater (GW), Surface/Storm Water (SW), Wastewater (WW), Recreational Water (RC), Soil/Solid (S), Oil (O), Wipe (W), Other (specify)

Preservative Types: HNO3(1), H2SO4(2), HCl(3), NaOH(4), Sodium Thiosulfate(5), Ammonium Chloride(6), Ammonium Sulfate(7), EDA(8), Hexane(9), Methanol(10), Sodium Bisulfate(11), Sodium Sulfite(12), Zinc Acetate(13), Unpreserved (U), Other (specify)

Requested Analysis

Sample Disposition [] Dispose as appropriate [] Return [] Archive

Received By (signature)

Date/Time

Received By (signature)

Date/Time

Received By (signature)

Date/Time

Reinquinished By (signature)

Date/Time

Reinquinished By (signature)

Date/Time

Reinquinished By (signature)

Date/Time

Reinquinished By (signature)

Date/Time

Reinquinished By (signature)

Date/Time

Reinquinished By (signature)

Date/Time

Reinquinished By (signature)

Date/Time

Reinquinished By (signature)

Date/Time

Reinquinished By (signature)

Date/Time

Reinquinished By (signature)

Date/Time

Reinquinished By (signature)

Date/Time

Reinquinished By (signature)

Date/Time

Reinquinished By (signature)

Lab Report Address

Turnaround Time

TO BE COMPLETED BY INITIAL RECEIVING MICROBAC:

Client Name: **De Ruyter Central School**
 Address: **711 Railroad St.**
 City, State, Zip: **De Ruyter, NY 13052**
 Contact: **Kevin Springer**
 Telephone No.: **315-852-3400 x7301**
 Report Email: **springer@deruytercentral.org**
 Send Report via: Mail Fax E-mail

Client Name: **SAME**
 Address:
 City, State, Zip:
 Contact:
 Telephone No.:
 Invoice Email:
 Send Invoice via: Mail Fax E-mail

Temperature Upon Receipt (°C):
 Thermometer ID:
 Receiving Lab: **CRT HBG PTN SAY**
 Holding Time:
 Samples Received on Ice? **Yes No N/A**
 Custody Seals Intact? **Yes No N/A**

Project: **De Ruyter School**
 Location: **De Ruyter School**
 PO No. **210506**
 Compliance Monitoring? Yes No
 If Yes: Agency/Program:
 Sampler Telephone No.: **315-852-3400 x 7301**

Report Type
 Results Only
 Level 1 Level 2 Level 3 Level 4
 EDD

Sampler Signature: **Kevin Springer**
 Sampler Telephone No.: **315-852-3400 x 7301**
 Matrix Types: Drinking Water (DW), Groundwater (GW), Surface/Storm Water (SW), Wastewater (WW), Recreational Water (RC), Soil/Solid (S), Oil (O), Wipe (W), Other (specify)
 Preservative Types: HNO3(1), H2SO4(2), HCl(3), NaOH(4), Sodium Thiosulfate(5), Ammonium Chloride(6), Ammonium Sulfate(7), EDA(8), Hexane(9), Methanol(10), Sodium Bisulfate(11), Sodium Sulfite(12), Zinc Acetate(13), Unpreserved (U), Other (specify)

Lab ID	Client Sample ID	Date Collected	Time Collected	No. of Containers	Matrix	Grab / Composite	Preservative	Lead Testing
97		6/24/21	6:39	1	DW Grab U			
98			6:41					
99			7:00					
100			7:01					
101			7:05					
102			7:06					

Requested Analysis
 Sample Disposition: Dispose as appropriate Return Archive
 Received By (signature) Date/Time
 Received By (signature) Date/Time
 Received By (signature) Date/Time

Possible Hazard Identification: Hazardous Non-Hazardous Radioactive
 Relinquished By (signature) Date/Time
 Relinquished By (signature) Date/Time
 Relinquished By (signature) Date/Time

Comments:
 Middle School Girls Right
 Rm. 223
 Rm. 224
 Guidance Booth
 Annex Girls Band
 Annex Boys Band

*** TO BE COMPLETED BY FINAL RECEIVING MICROBAC:
 Temperature Upon Receipt (°C):
 Thermometer ID:
 Receiving Lab: **CRT PTN**
 Samples Received on Ice? **Yes No N/A**

*** If Initial and Final Receiving Microbac are the same, check "Same as Above" in Final Receiving Box.

Page 46 of 48

Lab Report Address

Turnaround Time

TO BE COMPLETED BY INITIAL RECEIVING MICROBAC:

Client Name: **DeRuyter Central School**
 Address: **711 Railroad St.**
 City, State, Zip: **DeRuyter, NY 13052**
 Contact: **Kevin Springer**
 Telephone No.: **315-852-3400 x7301**
 Report Email: **springer@deruytercentral.org**
 Send Report via: Mail Fax E-mail

Client Name: **SAME**
 Address: **SAME**
 City, State, Zip:
 Contact:
 Telephone No.:
 Invoice Email:
 Send Invoice via: Mail Fax E-mail

Temperature Upon Receipt (°C):
 Thermometer ID:
 Receiving Lab: **GRT HBG PTN SAY**
 Holding Time:
 Samples Received on Ics? **Yes No N/A**
 Custody Seals Intact? **Yes No N/A**

Project: **DeRuyter School** PO No. **210506** Compliance Monitoring? Yes No
 If Yes: Agency/Program:
 Location: **DeRuyter School** PO No. **210506** Compliance Monitoring? Yes No
 If Yes: Agency/Program:
 Project: **DeRuyter School** PO No. **210506** Compliance Monitoring? Yes No
 If Yes: Agency/Program:

Sampler Signature: **Kevin Springer** Sampler Telephone No.: **315-852-3400 x 7301**
 Matrix Types: **Drinking Water (DW), Groundwater (GW), Surface/Storm Water (SW), Wastewater (WW), Recreational Water (RC), Soil/Solid (S), Sludge (SL), Oil (O), Wipe (W), Other (specify)**
 Preservative Types: **HNO3(1), H2SO4(2), HCl(3), NaOH(4), Sodium Thiosulfate(5), Ammonium Chloride(6), Ammonium Sulfate(7), EDA(8), Hexane(9), Methanol(10), Sodium Bisulfate(11), Sodium Sulfite(12), Zinc Acetate(13), Unpreserved (U), Other (specify)**

Instructions on back
 Number
 TO BE COMPLETED BY INITIAL RECEIVING MICROBAC:
 Temperature Upon Receipt (°C):
 Thermometer ID:
 Receiving Lab: **GRT HBG PTN SAY**
 Holding Time:
 Samples Received on Ics? **Yes No N/A**
 Custody Seals Intact? **Yes No N/A**

REQUESTED ANALYSIS

Lab ID	Client Sample ID	Date Collected	Time Collected	No. of Containers	Matrix	Grab / Composite	Preservative	Lead Testing
	103	6/24/21	7:07	1	DW Grab U			
	104		7:09					
	105		7:10					
	106		7:10					
	107		7:11					
	108		7:12					

Possible Hazard Identification Hazardous Non-Hazardous Radioactive
 Relinquished By (signature) _____ Date/Time _____
 Relinquished By (signature) _____ Date/Time _____
 Relinquished By (signature) _____ Date/Time _____
 Comments:
 Additional Notes: **Annex DF Rm. 403 Bath (Supt.) Weight Rm. BF Weight Rm. DF Weight Rm. sink Weight Rm. Bath**

Lab Report Address Invoice Address

Client Name: **DeRuyter Central School**
 Address: **711 Railroad St.**
 City, State, Zip: **DeRuyter, NY 13052**
 Contact: **Kevin Springer**
 Telephone No.: **315-852-3400 x 7301**
 Report Email: **springer@deruytercentral.org**
 Send Report via: Mail Fax E-mail

Client Name: **SAME**
 Address:
 City, State, Zip:
 Contact:
 Telephone No.:
 Invoice Email:
 Send Invoices via: Mail Fax E-mail

Turnaround Time

Routine (5-7 bus. days)
 RUSH* (notify lab)

Report Type

Results Only
 Level 1 Level 2 Level 3 Level 4
 EDD


TO BE COMPLETED BY INITIAL RECEIVING MICROBAC:

Temperature Upon Receipt (°C):
 Thermometer ID:
 Receiving Lab: **CRT HBG PTN SAY**
 Holding Time:
 Samples Received on Ice? **Yes No N/A**
 Custody Seals Intact? **Yes No N/A**

Project: **DeRuyter School** PO No. **210506** Compliance Monitoring? Yes No
 If Yes: Agency/Program:

Sampled by (PRINT): **Kevin Springer** Sampler Signature: *Kevin Springer*
 Sampler Telephone No.: **315-852-3400 x 7301**
 Matrix Types: **Drinking Water (DW), Groundwater (GW), Surface/Storm Water (SW), Wastewater (WW), Recreational Water (RC), Soil/Solid (S), Sludge (SL), Oil (O), Wipe (W), Other (specify)**
 Preservative Types: **HNO3(1), H2SO4(2), HCl(3), NaOH(4), Sodium Thiosulfate(5), Ammonium Chloride(6), Ammonium Sulfate(7), EDA(8), Hexane(9), Methanol(10), Sodium Bisulfate(11), Sodium Sulfite(12), Zinc Acetate(13), Unpreserved (U), Other (specify)**

REQUESTED ANALYSIS



Lab ID	Client Sample ID	Date Collected	Time Collected	No. of Containers	Matrix	Grab/Composite	Preservative	Lead Testing
109		6/24/21	7:13	1	DW Grab U			
110			7:14					
111			6:00					
112			6:01					
113								
114								

Possible Hazard Identification Hazardous Non-Hazardous Radioactive

Comments:

Sample Disposition Dispose as appropriate Return Archive

Received By (signature) Date/Time

Received By (signature) Date/Time

Received By (signature) Date/Time

Springer 6/25/21 1500

TO BE COMPLETED BY FINAL RECEIVING MICROBAC:

Temperature Upon Receipt (°C):
 Thermometer ID:
 Receiving Lab: **CRT PTN**
 Samples Received on Ice? **Yes No N/A**